

The following rules apply to connect your own packed electrical equipment to the Swedish Exhibitions electrical grid.

It is the exhibitor's full responsibility to ensure and document that own packed electrical equipment meets all applicable safety requirements.

Equipment that will be connected to the power grid must in all situations be secure to persons, domestic animals and property.

The requirements above should be fulfilled by comply the demands in Swedish Standard or in corresponding IEC-standard.
Especially IEC 60364-7-711 must be considered.

Before any Equipment is connected to the power grid a signed copy of **"Test protocol regarding Electricity on Exhibitions"** must be submitted to the Electrician in charge on Swedish Exhibition & Congress Centre.

If a different design than Swedish Standard or IEC is chosen, the electrical safety must be documented and a copy of the document must be submitted to the Electrician in charge on Swedish Exhibition & Congress Centre.

Testing protocol according to Swedish Standard SS 436 40 00 section 711.6 or IEC 60364-7-711.6 must be present.

The Swedish Exhibition & Congress Centre is allowed at any time perform security check in the Exhibition stand.

If any defective is observed and these are not corrected immediately The Swedish Exhibition & Congress Center have the right to unplug the equipment without any economical demands from the Exhibitioner.

If any injury will occur to persons, domestic animals or property and the cause is the own packed equipment, the Exhibitioner have the full responsibility to pay the whole cost that the injury has occurred.

The equipment must fulfill applicable EMC requirements to ensure that no disturbances is generated

If the equipment is a prototype or experimental and the EMC requirements not can be fulfilled, this must be informed when the Exhibition stand is ordered so The Swedish Exhibition & Congress Center can take the necessary steps to counteract to disturbances before the event starts.